

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client : Timba Flooring
29 Park Rd, Cheltenham
VIC 3192

Test Number : 19-001439
Issue Date : 22/03/2019
Print Date : 22/03/2019

Sample Description Clients Ref : Engineered Floor Boards
Timber floor boards
Colour : Oak
End Use : Flooring
Nominal Composition : Oak and Plywood
Nominal Thickness : 14-21mm

AS 4586-2013
Appendix A

Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Testing 20/03/2019
Test Temperature (20±5degC) 23 °C
Sample Preparation Washed with neutral pH detergent and then dried.
Test Direction Cross- direction
Fixed/Unfixed Unfixed
Slider No 96 Batch No 72

	1	2	3	4	5	SRV
British Pendulum Number	37	37	35	36	34	36

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 16/10/2017
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

Sample tested across the direction of grain as per clients instruction. No classification can be stated.

160321

34839

Page 1 of 1

© Australian Wool testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

- Chemical Testing
- Mechanical Testing
- Performance & Approvals Testing

: Accreditation No. 983
: Accreditation No. 985
: Accreditation No. 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



0204/11/06

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc. (Hons)
MANAGING DIRECTOR